



নর্দান ইলেকট্রিসিটি সাপ্লাই কোম্পানি পিএলসি

Northern Electricity Supply Company PLC

(An Enterprise of Bangladesh Power Development Board)

তত্ত্বাবধায়ক প্রকৌশলী (ক্রয়) এর দপ্তর, প্রধান কার্যালয়, বিদ্যুৎ ভবন, হেতেম খাঁ, রাজশাহী-৬০০০

www.nesco.gov.bd

Memo No: 27.29.0000.012.07.007.23-248

Date: 27/03/2023

Amendment of Tender Document

Tender Name: Procurement of 415V 0.5 Class 200/5A CT Operated Metering Unit for NESCO PLC
Tender Ref. No: 27.29.0000.012.07.007.23-188, Date: 06/03/2023

Section No.	Clause	Page No.	Existing Specification/Requirements	Shall Be Amended As
Section-5	Form PG4-3A, Form PG4-3B	77, 78	Period of Delivery as per Schedule of Requirement: within 120 (One Hundred and Twenty) days from the opening date of the letter of credit.	Period of Delivery as per Schedule of Requirement: within 150 (One Hundred and Fifty) days from the opening date of the letter of credit.
Section-6	A	92	120 days from the opening of L/C	150 days from the opening of L/C
Section-7	1.2 Memory Storage	96	The meter shall have sufficient capacity (minimum 1MB) to store the following readings and data in non-volatile memory even in case of power failure. <ul style="list-style-type: none">Number of power interruption with date & time (minimum 500 events)Inclusion of events and temper items are programmable. Typical items are Power Failure, Demand Reset, Time Change, History Log, Operator Code, Terminal Cover Open, Front Cover Open etc. The event & Temper log should be recorded with date and time in separate memory.....	'Front Cover Open' shall be deleted
Section-7	1.11 Event Log	103	The meter shall record the following events with time and date not less than 500 nos. as follows: Power failure (On/Off) with time and date, log in/log out with user ID, Time of USE (TOU) resetting and date change, terminal cover open, front cover open , tamper, PT failure, demand reset, any faults etc. Event log storage provision during configuration done in all cases are needed. These events record will be additional to the meter default event recording system.	'Front Cover Open' shall be deleted

All other terms & conditions shall remain unchanged.

২৭.০৩.২৩
(Md. Mizanur Rahman)
Superintending Engineer (Procurement)
NESCO PLC, Rajshahi