

## নর্দান ইলেকট্রিসিটি সাপ্লাই কোম্পানি লিমিটেড

Northern Electricity Supply Company Limited

(An Enterprise of Bangladesh Power Development Board) Bidyut Bhaban, Hetem khan, Rajshahi, Bangladesh. (Cell No: +88-01709-996750, E-mail: pd.rajpdp@nesco.gov.bd)



NESCO Ltd, Rajshahi, Bangladesh.

Date: 23/05/2022

Memo No: 27.29.0000.014.07.169.22-146

## 3rd Amendment

**Tender Name:** Procurement of "Design, Supply, Erection, Installation, Testing and Commissioning of 02(Two) Nos. New 33/11KV 2X10/13.33 MVA Substations Respectively at Nachol Gomostapur and Talora Dupchachiya on Turnkey Basis Under Extension & Renovation project of Distribution line & Substation 0f Rajshahi Division (ICT). Package-1, Lot-2"

Tender Ref. No: 27.29.0000.014.07.169.22-114 Date :13/04/2022

Amendment at Tender Notice/Document			
SI. No	Clause. No	Written as	Shall Be Amended (Replaced) As
1	ITT 24.2(r)	12) At least 01 (one) no. Manufacturer's Satisfactory Performance Certificates from Electricity Utility as End User depicting that each offered type or higher capacity rating Power Transformer, 33kV Outdoor VCB, 33kV PCM Panel, 11kV VCB with PCM Panel(11 KV AIS Switchgear Panel), Battery & Battery Charger, SAS(Substation Automation system), 11kV XLPE Power Cable, 33kV & 11kV LA, 33kV & 11kV CT & PT of same voltage class within last 10 (ten) years i.e. years counting backward from the date of publication of IFT in	12.a) For 33/11 KV 10/13.33 MVA Power Transformer only:  At least 01 (one) no. Manufacturer's Satisfactory Performance Certificates from Electricity Utility as End User or Supplied in any Industry/Plant which is Certified by Electricity Utility through official pad (official pad shall contain Utility office's full mailing address, e-mail address, website address and fax / telephone number for the convenience of authentication.) depicting that each offered type or higher capacity rating Power Transformer within last 05 (Five) years i.e. years counting backward from the date of publication of IFT in the newspaper and has been in satisfactorily service for at least 01(one) years. The Satisfactory Performance Certificate (SPC) shall be in Electricity Utility End User's official pad and shall contain end-user's full mailing address, e-mail address, website address and fax / telephone number for the convenience of authentication. (Note: The manufacturer must have Type Test Certificates & Reports for offered type or higher MVA rating power transformer for same voltage class from any short-circuit testing liaison (STL) Member [http://www.stl-liaison.org/web/03_Members.php] Testing Organization or Laboratory as per
		the newspaper and has been in satisfactorily service for at least 01(one) years. The Satisfactory Performance Certificate (SPC) shall be in End User's official pad and shall contain end-user's full mailing address, e-mail address, website address and fax / telephone number for the convenience of authentication. Note: Electricity Utility means an organization/company that engages in electricity generation/transmission / distribution of electricity for sale in a regulated market.	relevant IEC standard.)  12.b) For other 33/11 KV Substation Equipment's:  At least 01 (one) no. Manufacturer's Satisfactory Performance Certificates from Electricity Utility as End User depicting that each offered type or higher capacity rating 33kV Outdoor VCB, 33kV PCM Panel, 11kV VCB with PCM Panel(11 KV AIS Switchgear Panel), Battery & Battery Charger, SAS(Substation Automation system), 11kV XLPE Power Cable, 33kV & 11kV LA, 33kV & 11kV CT & PT of same voltage class within last 10 (ten) years i.e. years counting backward from the date of publication of IFT in the newspaper and has been in satisfactorily service for at least 01(one) years. The Satisfactory Performance Certificate (SPC) shall be in Electricity Utility End User's official pad and shall contain end-user's full mailing address, e-mail address, website address and fax / telephone number for the convenience of authentication.  Note: Electricity Utility means an organization/company that engages in electricity generation/ transmission / distribution of electricity for sale in a regulated market.
2	-	Last Date and time for Selling the tender document: 29/05/2022 up to 5:00 P.M (BST)	Last Date and time for Selling the tender document: 14/06/2022 up to 5:00 P.M (BST)
3	-	Last Date & Time for Submission of Tender: 30/05/2022, 11:00 A.M (BST)	Last Date & Time for Submission of Tender: 15/06/2022, 11:00 A.M (BST)
4	-	Tender Opening Date & Time: 30/05/2022, 11:30 A.M (BST)	Tender Opening Date & Time: 15/06/2022, 11:30 A.M (BST)

Note: This Amendment shall be a part of the tender document. All other terms & conditions shall remain unchanged.

Sd:-

(A B M Hamidur Rahman)
Project Director
vation project of Distribution line and Substati

Extension and Renovation project of Distribution line and Substation of Rajshahi Division NESCO Ltd, Rajshahi, Bangladesh.



## নর্দান ইলেকট্রিসিটি সাপ্লাই কোম্পানি লিমিটেড

Northern Electricity Supply Company Limited

(An Enterprise of Bangladesh Power Development Board) Bidyut Bhaban, Hetem khan, Rajshahi, Bangladesh. (Cell No: +88-01709-996750, E-mail: pd.rajpdp@nesco.gov.bd)



Office of Project Director Extension and Renovation project of Distribution line and Substation of Rajshahi Division NESCO Ltd, Rajshahi, Bangladesh.

## Copy to:

- 1. Managing Director, NESCO, Rajshahi.
- 2. Executive Director, Technical, NESCO, Rajshahi.
- 3. Chief Engineer, Services, NESCO, Rajshahi.
- 4. Superintending Engineer, Procurement, NESCO, Rajshahi
- 5. Superintending Engineer, Design & Inspection, NESCO, Rajshahi.
- 6. Deputy manager (Admin), for publishing in Daily newspaper.
- 7. Deputy manager (ICT), for publishing in Nesco Website.
- 8. Distribution to All Prospective Tenderers.
- 9. Office Copy.

(A B M Hamidur Rahman)

Project Director

Extension and Renovation project of Distribution line and Substation of Rajshahi Division

NESCO Ltd, Rajshahi, Bangladesh.