



NORTHERN ELECTRICITY SUPPLY COMPANY LIMITED

(An Enterprise of Bangladesh Power Development Board)

Bidyut Bhaban, Hetem Khan, Rajshahi, Bangladesh.

Tel: +88-0721-774900; E-mail: se_procurement@nesco.gov.bd; Web: www.nesco.gov.bd

Memo No: 27.29.0000.012.07.072.19-129

Date: 26/01/2020

2nd Amendment

Tender Name: Procurement of 33 KV and 11 KV Lightning Arrester (LA) for NESCO Ltd., Rajshahi.

Package No.: G-22


Invitation Reference No.: 27.29.0000.012.07.072.19-1396, **Date:** 15/12/2019.

A. Tender Notice:

| Sl. No. | Written As | Amended As |
|---------|---|---|
| 17 | Last Date and Time for Selling The Tender Document: 26/01/2020 up to 2.00 PM (BST) | Last Date and Time for Selling The Tender Document: 02/02/2020 up to 2.00 PM (BST) |
| 18 | Last Date and Time for Submission of Tender: 27/01/2020, 11.00 AM (BST) | Last Date and Time for Submission of Tender: 03/02/2020, 11.00 AM (BST) |
| 19 | Tender Opening Date and Time: 27/01/2020, 11.10 AM (BST) | Tender Opening Date and Time: 03/02/2020, 11.10 AM (BST) |

B. Technical Specification:

| Section No. | Page No. | Sl. No. | Written As | Amended As |
|-------------|----------|---------|---|---|
| 7 | 90 | 1.7.2 | The housing insulator of Lightning Arrester shall be wet process porcelain/polymer (Hydrophobic silicon) . | The housing insulator of Lightning Arrester shall be wet process polymer (Hydrophobic silicon) . |
| 7 | 98 | 1.7.2 | The housing insulator of Lightning Arrester shall be wet process porcelain/polymer (Hydrophobic silicon) . | The housing insulator of Lightning Arrester shall be wet process polymer (Hydrophobic silicon) . |
| 7 | 106 | 1.7.2 | The housing insulator of Lightning Arrester shall be wet process porcelain/polymer (Hydrophobic silicon) . | The housing insulator of Lightning Arrester shall be wet process polymer (Hydrophobic silicon) . |


26.01.2020
(Md. Ashiful Ahsan)
Manager (Procurement)

and

Superintending Engineer (Additional Charge)
procurement Department

NESCO Ltd., Bidyut Bhaban, Hetem Khan, Rajshahi