

### Amendment of Tender Document (GTP)

**Tender Name: Procurement of 3-Phase, 4-Wire Double Tariff Fully Programmable LT Whole Current Energy Meter with Enclosure for NESCO Ltd.**

**Tender Ref. No: 27.29.0000.012.07.068.20-75, Date: 11/01/2021**

Section No.	Clause	Page No.	Existing Specification/Requirements	Shall Be Amended As
Section-2	ITT 26.1(b)	36	Manufacturer's Authorisation Letter is required for all the items listed in Section 6: Schedule of Requirements.  Manufacturer's signature in authorization letter shall be handwritten by pen i.e. signature through stamping/seal is not accepted. The authorization letter shall mention e-mail address, Telephone/fax, designation with detail address of the manufacturer representative duly signed in the manufacturer official pad.	Manufacturer's Authorisation Letter is required for all the items listed in Section 6: Schedule of Requirements to Tenderer from authorized entities of manufacturer i.e. Dealer/ Trading House/ Manufacturer's Sales office (if located outside the manufacturer's country) will be accepted subject to submission of supporting document as authorized entities of manufacturer with the proposal.  Manufacturer's signature in authorization letter shall be handwritten by pen i.e. signature through stamping/seal is not accepted. The authorization letter shall mention e-mail address, Telephone/fax, designation with detail address of the manufacturer representative duly signed in the manufacturer official pad.
Section-7	3.3: Type Test	94	Type tests are required to prove the general design of the offered equipment/materials. The tenderer shall submit the type test reports of the offered equipment. Materials from internationally reputed independent testing laboratory as per latest version of relevant ANSI/IEC or equivalent international standards as mentioned in the contract.	Type tests are required to prove the general design of the offered equipment/materials. The tenderer shall submit the type test reports of the offered equipment. Materials from internationally reputed independent testing laboratory as per latest version of relevant ANSI/IEC or equivalent international standards as mentioned in the tender.
Section-8	8.1: SI. No. 04	96	Country of Origin: EU/North America/ Japan/ Australia/ USA/ UK	Country of Origin: To be mentioned
	8.1: SI. No. 44	97	-	Battery must be easily replaceable even if the meter is powered.
	8.2: SI. No. 03	98	Country of Origin: EU/North America/ Japan/ Australia/ USA/ UK/ China/ South Korea or equivalent	Country of Origin: To be mentioned

**All other terms & conditions shall remain unchanged.**

  
(17.02.2021)

(Md. Mizanur Rahman)  
Superintending Engineer (Procurement)  
NESCO Ltd., Rajshahi