



Northern Electricity Supply Company Limited
(An Enterprise of Bangladesh Power Development Board)
Bidyut Bhaban, Hetem Khan, Rajshahi, Bangladesh.

Tel: +8801709996750 (E-mail: pd.rangpdp@nesco.gov.bd, Web: www.nesco.gov.bd)

Memo No: 27.29.0000.015.07.233.22-2195

Date: 09/06/2022

Corrigendum-2

Subject: Minutes of the Pre-Tender Meeting and 2nd Amendment of Tender Document on Ref. No. 27.29.0000.015.07.233.22-2088 Issued on 19/04/2022 for Procurement of “Design, Supply, Installation, Testing and Commissioning of 02 nos 33/11KV, 2x10/13.33 MVA Regular Type New GIS Substation at Burimari, Patgram, Lalmonirhat & at Bhajanpur, Panchagarh on turnkey basis under Extension & Renovation Project of Distribution Line & Sub-Station for Rangpur Division, NESCO Ltd., Rangpur (ICT)”

A Pre-Tender Meeting was held on 09-06-2022 for Procurement of “Design, Supply, Installation, Testing and Commissioning of 02 nos 33/11KV, 2x10/13.33 MVA Regular Type New GIS Substation at Burimari, Patgram, Lalmonirhat & at Bhajanpur, Panchagarh on turnkey basis under Extension & Renovation Project of Distribution Line & Sub-Station for Rangpur Division, NESCO Ltd., Rangpur (ICT)”. The following Explanation/Amendment has been made on the basis of Pre-Tender Meeting discussion in the presence of prospective tenderers.

Tender Invitation Ref. No.: 27.29.0000.015.07.233.22-2088; 19/04/2022

Amendment at Tender Document			
Sl. No	Clause. No/Issue	Written as in Tender Document	Shall Be Amended (Replaced) As
1	Station Transformer GIS Breaker Rating & CT rating	1. Station Transformer GIS Breaker Rating-1600A 2. CT rating 600-1200/5-5A	1. Station Transformer GIS Breaker Rating-1250A 2. CT rating 200-400/5-5A <i>i.e. Same as Single Line Diagram</i>
2	Battery Set Rating	Battery Set Rating-100AH	Battery Set Rating-200AH
3	33 KV Incoming Dis-connector Switch	In SLD 33 KV Incoming Dis-connector Switch have shown.	In SLD 33 KV Incoming Dis-connector Switch have shown for pictorial view only. Actually 33 KV Dis-connector Switch will be build in inside GIS Panel.
4	Experience of GIS Switchgear Manufacturer		GIS Switchgear Manufacturer must have 15 (Fifteen) years of Manufacturing experience of GIS Switchgear.

Enclosure: Attendance Sheet

(D.M. Abu Hena Mostafa Kamal)
Project Director
Extension and Renovation Project of
Distribution Line & Sub-Station of
Rangpur Division, NESCO Ltd.,
Rangpur

Copy To:










1. Managing Director, NESCO Ltd.
2. Executive Director (Technical), NESCO, Ltd.
3. Deputy Manager (Accounts), Rangpur Division Power Distribution Project, NESCO Ltd.
4. Deputy Manager, Admin, NESCO Ltd., Rajshahi.
5. Deputy Manager, ICT (for publishing in NESCO Website), NESCO Ltd., Rajshahi.
6. Office Copy.

বিভাগ বিদ্যুৎ বিতরণ প্রকল্প, নেসকো লি., রংপুর এর আওতায় মোট ০২ (দুই) টি নতুন জিআইএস উপকেন্দ্র স্থাপন

কাজের Pre-Tender/Pre-Bid সভায় উপস্থিতির তালিকা

স্থান: প্রকল্প পরিচালকের দপ্তর, রংপুর প্রকল্প, রুম-৫১০, নেসকো প্রধান কার্যালয়, বিদ্যুৎ ভবন, হেতেম খাঁ, রাজশাহী।

তারিখ: ০৯/০৬/২০২২ খ্রি:; সময়: সকাল-১১:৩০ টা

ক্র: নং	নাম	পদবী	দপ্তর/সংস্থা	মোবাইল ও ই-মেইল	স্বাক্ষর
১	শ্রী: জাহিদ সাদিক	ম্যানেজার (টেক)	টিএস ট্রান্সফর্মার রুম নিমিটেড.	০১৭৩৭৫৫০৯০৫ jahid.sagroup@gmail.com	
২	MD. SOHEL RANA	Manager	TS Transformer LTD, Manager.	01717244307 Sohelsk@gmail.com	
৩	Hasan Mohammad Zahid	AE. Engineer	Energy Pac Engineering Ltd	01711-123700 01708-131707 zahid.pabona9576@gmail.com	
৪	MD. Anisur Rahman	SDE	Rangpur Project NESCO	01785-219743	
৫	Apurbo Ky Datta	Sr. Asst. M (SEM)	"Angelique BBSEL JV"	01730-739560 rafiq@bbscables.com.bd	
৬	IRFAN UL HOQUE	SDE	Rangpur Project	01747883831	
৭	MD. Maruful Haque	SDE	Rajshahi Project	01723-552903 maruful.haque@nesco.gov.bd	
৮	MD. Mehat Hasan	SAE	Rangpur Project	01796-896184 hasan.mehat@nesco.gov.bd	
৯	Gopinath Chandra Saha	XEN,	Rajshahi Project	01321124482	
১০					
১১					