

Sub: Minutes of the Pre-Tender Meeting and 1st Amendment of Tender Document on Ref. No. 27.29.0000.012.07.014.21-254 Issued on 10.02.2021 for Procurement of “Design, Supply, Erection, Installation, Testing and Commissioning for Upgradation of Citycentral, Bindurmore, Hujrapur and Bottola , 33/11 KV Substation on Turnkey Basis under Rajshahi Division Power Distribution Project (ICT)” -Package:3, Lot:1.

A Pre-Tender Meeting was held on 04-04-2021 on Ref. No. 27.29.0000.012.07.014.21-254 issued on 10.02.2021 for Procurement of “Design, Supply, Erection, Installation, Testing and Commissioning for Upgradation of Citycentral, Bindurmore, Hujrapur and Bottola, 33/11 KV Substation on Turnkey Basis under Rajshahi Division Power Distribution Project (ICT)”. The following Explanation/Amendment has been made on the basis of Pre-Tender Meeting discussion in the presence of prospective tenderers.

SL No	Clause No & Name	Queries/Written as	Explanation/Amendment
01	ITT 14.1 (a) General Experience	The Tenderer shall have a minimum of Five (05) years of overall experience in the business of Supply, Installation, Erection, Testing, Commissioning of electrical substation in govt./semi govt./autonomous electricity utilities in Bangladesh in the role of contractor or management contractor (years counting backward from the date of IFT).	The Tenderer shall have a minimum of five (05) years of overall experience in the business of supply, Installation, Erection, Testing, Commissioning of electrical substation in electricity utilities in the role of contractor or management contractor (years counting backward from the date of IFT).
02	ITT 14.1 (b) Specific Experience	The minimum specific experience as a Contractor or Management Contractor in similar to the proposed plant and services in at least a number of 2 (two) contract(s) of similar nature*, complexity and methods/construction technology successfully completed within the last 10 (ten) years (years counting backward from the date of IFT), each with	The minimum specific experience as a Contractor or Management Contractor in similar to the proposed plant and services in at least a number of 2 (two) contract(s) of similar nature*, complexity and methods/construction technology successfully completed within the last 10 (ten) years (years counting backward from the date of IFT), each

SL No	Clause No & Name	Queries/Written as	Explanation/Amendment
		<p>a value of at least Tk. 13 Crore (BDT Thirteen Crore) in govt./semi govt./autonomous electricity utilities in Bangladesh.</p> <p>In addition, performance of the completed turnkey contracts and ongoing turnkey contract(s) as mentioned in Annexure: 5-1 and Annexure: 5-2 shall be taken into consideration during evaluation.</p> <p><u>Note:</u></p> <ol style="list-style-type: none"> <i>The Tenderer shall have to submit End User Certificate(s) in End User's official pad; in favor of above-mentioned experience stating that the performance of the supplied plant and services are satisfactory for at least one (01) year.</i> <i>The End User Certificate(s) duly signed by the end user shall mention the name & commissioning date of the plant and services which were designed, supplied, installed/constructed, tested and commissioned by Tenderer (lead partner in case of JV) and shall contain end-user's full mailing address, e-mail address, website address, fax number and phone number for the convenience of authentication. In any case, NESCO reserve the right to verify genuineness of End User Certificate(s).</i> <i>Certificate(s) those are not in Bangla/English must be notarized on translated English version.</i> <p><i>*Similar nature means: Constriction of 33/11kV or higher voltage level GIS/AIS/GIS+AIS Substation and having capacity regarding engineering, supply, erection, installation, testing and commissioning of at least 2x10/13.33MVA or higher capacity substations on turnkey basis.</i></p>	<p>with a value of at least Tk. 13 Crore (BDT Thirteen Crore) in Electricity Utility.</p> <p>In addition, performance of the completed turnkey contracts and ongoing turnkey contract(s) as mentioned in Annexure: 5-1 and Annexure: 5-2 shall be taken into consideration during evaluation.</p> <p><u>Note:</u></p> <ol style="list-style-type: none"> <i>The Tenderer shall have to submit End User Certificate(s) in End User's official pad; in favor of above-mentioned experience stating that the performance of the supplied plant and services are satisfactory for at least one (01) year.</i> <i>The End User Certificate(s) duly signed by the end user shall mention the name & commissioning date of the plant and services which were designed, supplied, installed/constructed, tested and commissioned by Tenderer (lead partner in case of JV) and shall contain end-user's full mailing address, e-mail address, website address, fax number and phone number for the convenience of authentication. In any case, NESCO reserve the right to verify genuineness of End User Certificate(s).</i> <i>Certificate(s) those are not in Bangla/English must be notarized on translated English version.</i> <i>Electricity Utility means an organization/company that engages in electricity generation/ transmission / distribution of electricity for sale in a regulated market.</i> <p><i>*Similar nature means: Construction of 33/11kV or higher voltage level GIS/AIS/GIS+AIS Substation and having capacity regarding engineering, supply, erection, installation, testing and commissioning of at least 2x10/13.33MVA or higher capacity substations on turnkey basis.</i></p>
03	ITT 24.2(r)-12	<p>At least 02 (two) nos. Manufacturer's Satisfactory Performance Certificates from Electricity Utility as End User depicting that each offered type or higher capacity rating Power Transformer, 33kV Outdoor VCB, 33kV PCM Panel, 11kV VCB with PCM Panel, Battery & Battery Charger, 11kV XLPE Power Cable, 33kV & 11kV LA, CT & PT of same voltage class within last 10 (ten) years i.e. years counting backward from the date of publication of IFT in the newspaper and has been in satisfactorily service for at least 02(two) years. The Satisfactory Performance Certificate (SPC) shall be in End User's official pad and shall contain end-user's full mailing address, e-mail address, website address and fax / telephone number for the convenience of authentication.</p> <p><u>Note: Electricity Utility means govt./semi govt./autonomous electricity utilities engaged in Bangladesh.</u></p>	<p>At least 02 (two) nos. Manufacturer's Satisfactory Performance Certificates from Electricity Utility as End User depicting that each offered type or higher capacity rating Power Transformer, 33kV Outdoor VCB, 33kV PCM Panel, 11kV VCB with PCM Panel, Battery & Battery Charger, 11kV XLPE Power Cable, 33kV & 11kV LA, CT & PT of same voltage class within last 10 (ten) years i.e. years counting backward from the date of publication of IFT in the newspaper and has been in satisfactorily service for at least 02(two) years. The Satisfactory Performance Certificate (SPC) shall be in End User's official pad and shall contain end-user's full mailing address, e-mail address, website address and fax / telephone number for the convenience of authentication.</p> <p><u>Note: Electricity Utility means an organization/company that engages in electricity generation/ transmission / distribution of electricity for sale in a regulated market.</u></p> <p><i>Certificate(s) those are not in Bangla/English must be notarized on translated English version.</i></p>


SL No	Clause No & Name	Queries/Written as	Explanation/Amendment
04	ITT 37.1	In addition to the original of the Tender, 3 (three) copies shall be submitted within the date and time mentioned in the Tender Notice.	In addition to the original of the Tender, 1(one) copy shall be submitted within the date and time mentioned in the Tender Notice. All documents must be book binding with page number & index.
05	Section -5 (Schedules of Rates and Prices) Schedule No. a (1) - Row no. 24, Schedule No. a(2) - Row no. 24, Schedule No. b (1) - Row no. 06, Schedule No. b(2) - Row no. 06, Schedule No. c (1) - Row no. 23, Schedule No. c(2) - Row no. 23, Schedule No. d (1) - Row no. 16, Schedule No. d(2) - Row no. 16, Section -6 (6.1.2.1 - Row no. 24, 6.1.2.2 - Row no. 06, 6.1.2.3 - Row no. 23, 6.1.2.4 - Row no. 16 etc.	Supply of 11 KV 2000A, 31.5 KA for 3 sec Transformer incoming panel comprising 3 phase busbars 2500A including 11 KV CT (1800-900/5-5-5A), 11kv PT, 3 Over Current + 2 Earth Fault (1 EF + 1 REF) + Directional Over Current Relays, Ammeters, Voltmeters, kWh m. (As per scope of works, Technical Specification and GTP)	Supply of 11 KV Transformer incoming panel comprising 3 phase busbars 2500A, VCB 2000A (31.5 KA for 3 sec) ,11 KV CT (1800-900/5-5-5A), 11KV PT, 3 Over Current + 2 Earth Fault (1 EF + 1 REF) + Directional Over Current Relays, Ammeters, Voltmeters, kWh m and all other accessories as required. (As per scope of works, Technical Specification and GTP)
06	Section -5 (Schedules of Rates and Prices) Schedule No. a (1) - Row no. 25, Schedule No. a(2) - Row no. 25, Schedule No. b (1) - Row no. 07, Schedule No. b(2) - Row no. 07, Schedule No. c (1) - Row no. 24, Schedule No. c (2) - Row no. 24, Schedule No. d (1) - Row no. 17, Schedule No. d(2) - Row no. 17, Section -6 (6.1.2.1 - Row no. 25, 6.1.2.2 - Row no. 07, 6.1.2.3 - Row no. 24, 6.1.2.4 - Row no. 17) etc.	Supply of overhead 11 KV 630A, 31.5 KA for 3 sec Line Feeder panels, comprising 3 phase busbars 2500A, including 11 KV CT (200-400/5-5A),two pole OC and single pole EF Relays for IDMT protection, Ammeters, Voltmeters , kWh m, HV and LV isolating plug and sockets draw out type VCB with auxiliary switches operating mechanism etc (As per scope of works, Technical Specification and GTP)	Supply of 11 KV overhead Line Feeder panels comprising 3 phase busbars 2500A, VCB 630A (31.5 KA for 3 sec), 11 KV CT (200-400/5-5A) two pole OC and single pole EF Relays for IDMT protection, Ammeters, Voltmeters, kWh m, HV and LV isolating plug and sockets draw out type VCB with auxiliary switches operating mechanism and all other accessories as required (As per scope of works, Technical Specification and GTP)
07	Section -5 (Schedules of Rates and Prices) Schedule No. a (1) -	Supply of 11 KV 2000A, 31.5 KA for 3 sec bus-coupler panel with bus raiser including 11 KV CT (1800-900/5-5-5A), 2 Over Current + 1 Earth Fault and all other accessories as required (As per scope of works, Technical Specification and GTP)	Supply of 11 KV bus-coupler panel with bus raiser comprising 3-Phase bus bars 2500A, VCB 2000A (31.5 KA for 3 sec), 11 KV CT (1800-900/5-5-5A), 2 Over Current + 1 Earth Fault and all other accessories as required (As per scope of works, Technical Specification and GTP)

SL No	Clause No & Name	Queries/Written as	Explanation/Amendment																								
	Row no. 26, Schedule No. a (2) - Row no. 26, Schedule No. b (1) - Row no. 08, Schedule No. b(2) - Row no. 08, Schedule No. c (1) - Row no. 25, Schedule No. c(2) - Row no. 25, Schedule No. d (1) - Row no. 18, Schedule No. d(2) - Row no. 18, Section -6 (6.1.2.1 - Row no. 26, 6.1.2.2 - Row no. 08, 6.1.2.3 - Row no. 25, 6.1.2.4 - Row no. 18) etc.																										
08	GTP No-8.03 Sl. No-100	The PCM Panel Shall be complied all the technical specification mentioned in Section-7	The PCM Panel Shall be complied all the technical specifications mentioned in Section-7 and GTP no-8.11 & 8.13																								
09	GTP No-8.11	Guaranteed Technical Particulars of 11kV Indoor Bushing /Ring Type Single Phase Current Transformer for regular substation	Guaranteed Technical Particulars of 11KV Indoor Bushing /Ring Type Single Phase Current Transformer for regular substation (11 KV switchgear)																								
10	GTP No-8.13	Guaranteed Technical Particulars of 11kV Indoor Type Single Phase Potential Transformer for regular substation	Guaranteed Technical Particulars of 11kV Indoor Type Single Phase Potential Transformer for regular substation (11 KV switchgear)																								
11	Section - 8.05 Guaranteed Technical Particulars of 11kV Pole mounted Off-Load Isolator with Earth Blade (Newly Added)		<p>Following Rows to be added</p> <table border="1"> <tr> <td>Current density at the minimum cross Section of</td> <td>Amps/ Sq.mm</td> <td>To be mentioned</td> <td></td> </tr> <tr> <td>a) Moving Blade</td> <td></td> <td></td> <td></td> </tr> <tr> <td>b) Terminal Pad</td> <td></td> <td></td> <td></td> </tr> <tr> <td>c) Contacts</td> <td></td> <td></td> <td></td> </tr> <tr> <td>d) Terminal Connector</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Maximum Temp. rise of current carrying parts when carrying rated current continuously (deg. C)</td> <td>deg. C</td> <td>To be mentioned</td> <td></td> </tr> </table>	Current density at the minimum cross Section of	Amps/ Sq.mm	To be mentioned		a) Moving Blade				b) Terminal Pad				c) Contacts				d) Terminal Connector				Maximum Temp. rise of current carrying parts when carrying rated current continuously (deg. C)	deg. C	To be mentioned	
Current density at the minimum cross Section of	Amps/ Sq.mm	To be mentioned																									
a) Moving Blade																											
b) Terminal Pad																											
c) Contacts																											
d) Terminal Connector																											
Maximum Temp. rise of current carrying parts when carrying rated current continuously (deg. C)	deg. C	To be mentioned																									
12	Section 8 - GTP of connectors: 8.03 [Row No:76]	Internal Arc Classification IAC A FLR- 31.5 KA for 1 sec	Internal Arc Classification IAC A FLR- 31.5 KA for 1 sec (Must be supported by type test report from any short-circuit testing liaison (STL) Member [http://www.stl-liaison.org/web/03_Members.php] Testing Organization or Laboratory as per relevant IEC standard).																								
13	Section 8 - GTP of connectors: 8.38 (Newly Added)	-	GTP & Drawing of all the required connectors has to be provided. Here for example; GTP & Drawing of T-TYPE CONNECTOR (36/25 mm) has been provided. Few other connectors are - 33 KV FLAT I-TYPE CONNECTOR (25 mm), 33 KV Double I-TYPE CONNECTOR (25/25 mm), 33 KV Double I-TYPE CONNECTOR (36/25 mm), PG Clamp (ACSR Grosbeak) etc. If any other type connectors are to be																								

SL No	Clause No & Name	Queries/Written as	Explanation/Amendment																																																
			<p>used, then GTP & Drawing of the same items must be provided. Dimensions of all the connectors have to be similar to the attached drawing here. Dimensions of connectors are subject to approval from NESCO.</p> <p>GUARANTEED TECHNICAL PARTICULARS (GTP) FOR 33 KV T-TYPE CONNECTOR (36/25 mm)</p> <table border="1" data-bbox="1239 321 1984 1396"> <thead> <tr> <th data-bbox="1247 321 1325 446">Sl. No.</th> <th data-bbox="1325 321 1526 446">Description</th> <th data-bbox="1526 321 1812 446">NESCO's Requirement</th> <th data-bbox="1812 321 1976 446">Manufacturer's Particulars</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="1247 446 1976 487">Compatible for ACSR MARTIN to ACSR GROSBEAK</td> </tr> <tr> <td data-bbox="1247 487 1325 581">1.</td> <td data-bbox="1325 487 1526 581">Name & Address of the Manufacturer</td> <td data-bbox="1526 487 1812 581">Shall be mentioned</td> <td data-bbox="1812 487 1976 581"></td> </tr> <tr> <td data-bbox="1247 581 1325 643">2.</td> <td data-bbox="1325 581 1526 643">Manufacturer's Code No.</td> <td data-bbox="1526 581 1812 643">Shall be mentioned</td> <td data-bbox="1812 581 1976 643"></td> </tr> <tr> <td data-bbox="1247 643 1325 737">3.</td> <td data-bbox="1325 643 1526 737">Applicable Standard</td> <td data-bbox="1526 643 1812 737">BS, IEC, BDS or equivalent international standard</td> <td data-bbox="1812 643 1976 737"></td> </tr> <tr> <td data-bbox="1247 737 1325 831">4.</td> <td data-bbox="1325 737 1526 831">Installation</td> <td data-bbox="1526 737 1812 831">Outdoor and shall be installed for the above-mentioned conductor.</td> <td data-bbox="1812 737 1976 831"></td> </tr> <tr> <td data-bbox="1247 831 1325 867">5.</td> <td data-bbox="1325 831 1526 867">Type</td> <td data-bbox="1526 831 1812 867">Bolted Type</td> <td data-bbox="1812 831 1976 867"></td> </tr> <tr> <td data-bbox="1247 867 1325 928">6.</td> <td data-bbox="1325 867 1526 928">Material</td> <td data-bbox="1526 867 1812 928">Aluminium Alloy (LM6 or higher grade)</td> <td data-bbox="1812 867 1976 928"></td> </tr> <tr> <td data-bbox="1247 928 1325 1146">7.</td> <td data-bbox="1325 928 1526 1146">Minimum continuous current rating at 35°C rise over 40°C ambient temperature (75°C)</td> <td data-bbox="1526 928 1812 1146">Shall be mentioned and capable of carrying the continuous current of the specified conductor in Amps.</td> <td data-bbox="1812 928 1976 1146"></td> </tr> <tr> <td data-bbox="1247 1146 1325 1269">8.</td> <td data-bbox="1325 1146 1526 1269">All Dimensions, Dia and Hole Size</td> <td data-bbox="1526 1146 1812 1269">Shall be as per drawing (Drg. No. 7.2) (To be confirmed)</td> <td data-bbox="1812 1146 1976 1269"></td> </tr> <tr> <td data-bbox="1247 1269 1325 1331">9.</td> <td data-bbox="1325 1269 1526 1331">Weight of 100 nos. in Kg</td> <td data-bbox="1526 1269 1812 1331">Shall be mentioned</td> <td data-bbox="1812 1269 1976 1331"></td> </tr> <tr> <td data-bbox="1247 1331 1325 1396">10.</td> <td data-bbox="1325 1331 1526 1396">Dimensional Drawing</td> <td data-bbox="1526 1331 1812 1396">Shall be enclosed</td> <td data-bbox="1812 1331 1976 1396"></td> </tr> </tbody> </table>	Sl. No.	Description	NESCO's Requirement	Manufacturer's Particulars	Compatible for ACSR MARTIN to ACSR GROSBEAK				1.	Name & Address of the Manufacturer	Shall be mentioned		2.	Manufacturer's Code No.	Shall be mentioned		3.	Applicable Standard	BS, IEC, BDS or equivalent international standard		4.	Installation	Outdoor and shall be installed for the above-mentioned conductor.		5.	Type	Bolted Type		6.	Material	Aluminium Alloy (LM6 or higher grade)		7.	Minimum continuous current rating at 35°C rise over 40°C ambient temperature (75°C)	Shall be mentioned and capable of carrying the continuous current of the specified conductor in Amps.		8.	All Dimensions, Dia and Hole Size	Shall be as per drawing (Drg. No. 7.2) (To be confirmed)		9.	Weight of 100 nos. in Kg	Shall be mentioned		10.	Dimensional Drawing	Shall be enclosed	
Sl. No.	Description	NESCO's Requirement	Manufacturer's Particulars																																																
Compatible for ACSR MARTIN to ACSR GROSBEAK																																																			
1.	Name & Address of the Manufacturer	Shall be mentioned																																																	
2.	Manufacturer's Code No.	Shall be mentioned																																																	
3.	Applicable Standard	BS, IEC, BDS or equivalent international standard																																																	
4.	Installation	Outdoor and shall be installed for the above-mentioned conductor.																																																	
5.	Type	Bolted Type																																																	
6.	Material	Aluminium Alloy (LM6 or higher grade)																																																	
7.	Minimum continuous current rating at 35°C rise over 40°C ambient temperature (75°C)	Shall be mentioned and capable of carrying the continuous current of the specified conductor in Amps.																																																	
8.	All Dimensions, Dia and Hole Size	Shall be as per drawing (Drg. No. 7.2) (To be confirmed)																																																	
9.	Weight of 100 nos. in Kg	Shall be mentioned																																																	
10.	Dimensional Drawing	Shall be enclosed																																																	

SL No	Clause No & Name	Queries/Written as	Explanation/Amendment
			<p>DRAWING OF 33 KV T-TYPE CONNECTOR (36/25 mm)</p>
14	Section -8 GTP 8.18 - Row No. - 10.4	NEUTRAL BUSHING CTS 11 KV FOR SEF & REF PROTECTION Ratio - 1800/5 A	NEUTRAL BUSHING CTS 11 KV FOR SEF & REF PROTECTION Ratio - 1800/5/5 A

Note: This Amendment shall be a part of the tender document. All other terms & conditions shall remain unchanged.


 (Md. Mizanur Rahman)
 Superintending Engineer
 Procurement Department
 NESCO, Rajshahi.

Copy to:

1. Managing Director, NESCO, Rajshahi.
2. Executive Director, Technical, NESCO, Rajshahi.
3. Chief Engineer, Services, NESCO, Rajshahi.
4. Project Director, Extension & Renovation Project of Distribution Line & Sub-Station for Rajshahi Division, Rajshahi.
5. Superintending Engineer, Design & Inspection, NESCO, Rajshahi.
6. Distribution to All Prospective Tenderers.
7. Office Copy.